

Certificate

This test result summary is awarded to:

The Window Glass Company (Bristol) Ltd.

11 Emery Road
Brislington
Bristol
BS4 5PF

WGL 800 Series Window - Tilt Turn next to Fixed Light

Doorset as specified in TR1397/C has successfully **PASSED**

When tested in accordance with:


BS6375-1: 2009 Performance of windows and doors.
Test methods: BS EN 1026, BS EN 1027 and BS EN 12211


Test type	Test Pressure (Pa) & Test Class
Air permeability	600 Pa / Class 2
Watertightness under static pressure	600 Pa / Class 7A
Wind resistance	2400 Pa / Class E

Average air classification for overall area	Class Four
Average air classification for joint area	Class Four

*** SAMPLE ACHIEVED AN EXPOSURE CATEGORY OF: 2000 +**

This test result summary is only valid when read in conjunction with test report: TR1397/C.

Signed on behalf of Winkhaus laboratories:  Date: 03/04/2014
Mr. Ross Howitt-Page. Senior Laboratory Technician

Signed on behalf of Winkhaus laboratories:  Date: 03.04.2014
Mr. Ade Collins. Laboratory Manager

This test result summary shall not be reproduced except in full, without the written authority of Winkhaus Laboratory.

Issue 1	03 / 04 / 2014	Original copy
---------	----------------	---------------