

## Certificate

This test result summary is awarded to:

### The Window Glass Company (Bristol) Ltd.

11 Emery Road  
Brislington  
Bristol  
BS4 5PF

#### PATT 10 (Fully Glazed) WGL 800 RAL Single Leaf Open-Out Doorset

Doorset as specified in TR1473/C2 has successfully **PASSED**

When tested in accordance with:


**BS6375-1: 2009** Performance of windows and doors.  
Test methods: BS EN 1026, BS EN 1027 and BS EN 12211


Test type	Test Pressure (Pa) & Test Class
<b>Air permeability</b>	600 Pa / Class 2
<b>Watertightness under static pressure</b>	750Pa / Class 3A
<b>Wind resistance</b>	1200 Pa / Class A3

<b>Average air classification for overall area</b>	Class Three
<b>Average air classification for joint area</b>	Class Three

**\* SAMPLE ACHIEVED AN EXPOSURE CATEGORY OF: 1200**

This test result summary is only valid when read in conjunction with test report: TR1473/C2.

Signed on behalf of Winkhaus laboratories:  Date: 17/03/2015.  
Mr. Ross Howitt Page. Senior Laboratory Technician

Signed on behalf of Winkhaus laboratories:  Date: 17-03-2015  
Mr. Ade Collins. Laboratory Manager

This test result summary shall not be reproduced except in full, without the written authority of Winkhaus Laboratory.

Issue 1	17 / 03 / 2015	Original copy
---------	----------------	---------------