

Certificate

This test result summary is awarded to:

The Window Glass Company (Bristol) Ltd

11 Emery Road
Brislington
Bristol
BS4 5PF

WGL 800 RAL Top Hung Next To Fixed Light Casement Window

Windows as specified in TR1485 have successfully: **PASSED**

When tested in accordance with:

Test type	Result
BS6375-1: 2009 Clauses: 6, 7 and 8	Air permeability: 600 Pa / Class 2 Watertightness: 600 Pa / Class 7A Wind resistance: 2400 Pa / Class AE
BS6375-1: 2009 Clauses: 6, 7 and 8	Average air classification for overall area: Class Four Average air classification for opening joint: Class Three Exposure category: 2000+

This test result summary is only valid when read in conjunction with test report: TR1485.

Signed on behalf of Winkhaus laboratories: _____

Date: 12/05/2015.

Mr. Ross Howitt-Page. Senior Laboratory Technician

Signed on behalf of Winkhaus laboratories: _____

Date: 12.05.2015.

Mr. Ade Collins. Laboratory Manager



This test result summary shall not be reproduced except in full, without the written authority of Winkhaus Laboratory.

Issue 1	12 / 05 / 2015	Original copy
---------	----------------	---------------