

## Certificate

This test result summary is awarded to:

### The Window Glass Company (Bristol) Ltd

11 Emery Road  
Brislington  
Bristol  
BS4 5PF

#### WGL 800 RAL Parallel Opening Window

Windows as specified in TR1486 have successfully: **PASSED**

When tested in accordance with:

Test type	Result
<b>PAS24: 2012</b> Clauses: C.4.3, C.4.4.2, C.4.4.3, C.4.5 and C.4.6.	PASS Window classification: W KT
<b>BS6375-1: 2009</b> Clauses: 6, 7 and 8	Air permeability: 600 Pa / Class 2 Watertightness: 900 Pa / Class 7A Wind resistance: 2400 Pa / Class AE
<b>BS6375-1: 2009</b> Clauses: 6, 7 and 8	Average air classification for overall area: Class Three Average air classification for opening joint: Class Two Exposure category: 2000+

This test result summary is only valid when read in conjunction with test report: TR1486.

Signed on behalf of Winkhaus laboratories: \_\_\_\_\_ Date: 12/05/2015  
Mr. Ross Howitt-Page. Senior Laboratory Technician

Signed on behalf of Winkhaus laboratories: \_\_\_\_\_ Date: 12.05.2015  
Mr. Ade Collins. Laboratory Manager



This test result summary shall not be reproduced except in full, without the written authority of Winkhaus Laboratory.

Issue 1	12 / 05 / 2015	Original copy
---------	----------------	---------------